



Danfoss A/S

6430 Nordborg
Denmark
CVR nr.: 20 16 57 15

Telephone: +45 7488 2222
Fax: +45 7449 0949

EU DECLARATION OF CONFORMITY

Danfoss A/S
Danfoss DEN Controls

declares under our sole responsibility that the

Product category: JIP Ball Valves

Type designation(s): JIP

PN(PS)	DN <=32	DN 40	DN 50	DN 65	DN 80	DN 100	DN 125	DN 150	DN 200	DN 250	DN 300	DN 350	DN 400	DN 450	DN 500	DN 600
6	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II
10	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II	Cat. II	Cat. II	Cat. III
16	Art. 4 §3	Art. 4 §3	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II	Cat. II	Cat. III	Cat. III	Cat. III	Cat. III	Cat. III
25	Art. 4 §3	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II	Cat. II	Cat. II	Cat. III	Cat. III	Cat. III	Cat. III	Cat. III	Cat. III
40	Art. 4 §3	Cat. I	Cat. I	Cat. I	Cat. I	Cat. I	Cat. II	Cat. II	Cat. II	Cat. II	Cat. III	Cat. III	Cat. III	Cat. III	Cat. III	Cat. III

Covered by this declaration is in conformity with the following directive(s), standard(s) or other normative document(s), provided that the product is used in accordance with our instructions.

Pressure Equipment Directive 2014/68/EU

- | | |
|-----------------|---|
| EN 19:2016 | Industrial valves - Marking of metallic valves |
| EN 1092-1:2018 | Flanges and their joints - Circular flanges for pipes, valves, fittings and accessories, PN designated - Part 1: Steel flanges |
| EN 12266-1:2012 | Industrial valves - Testing of metallic valves - Part 1: Pressure tests, test procedures and acceptance criteria - Mandatory requirements |

Date: 2019.03.26 Place of issue: Ljubljana	Issued by Signature: Name: Sandro Terzić Title: Mechanical Portfolio Manager	Date: 2019.03.26 Place of issue: Ljubljana	Approved by Signature: Name: Aleksander Zalaznik Title: Senior Vice President DEN SC
--	--	--	--

Danfoss only vouches for the correctness of the English version of this declaration. In the event of the declaration being translated into any other language, the translator concerned shall be liable for the correctness of the translation


Conformity assessment procedure according to

Module H - Full quality assurance.

A risk assessment has been performed and documented according to Annex I.

Products belong to PED Article 4 paragraph 3 (Art. 4.3) are not CE marked.


Products in category I, II and III that are manufactured before and include 2019-03-29 are marked with

0041 and evaluated by:

Bureau Veritas UK, Parklands, Wilmslow Road
Didsbury, Manchester,
M20 2RE - United Kingdom

Certificate issued:

CE-0041-PED-H-DAN 001-18-DNK

Products in category I, II and III that are manufactured as of 2019-03-30 are marked with 0062 and evaluated by:

BUREAU VERITAS
Newtime - 52 Boulevard du Parc - Ile de la Jatte
92200 Neuilly sur Seine
France

Certificate issued:

CE-0062-PED-H-DAF 002-19-DNK